

RADIATORLISTE

Nr.	Stk.	Type RIO	Længde mm	Eff. ydelse Δt 30 °C	Anboringer	Radiator ventil	Bemærkninger
1	2	PKP 955	800	847	4 x 1/2"	VD115-11	
2	2	PKP 655	1000	773	4 x 1/2"	VD115-11	
3	2	PKP 655	700	541	4 x 1/2"	VD115-11	
4	1	PKP 555	1000	676	4 x 1/2"	VD115-11	
5	4	PKP 455	1500	829	4 x 1/2"	VD115-11	
6	1	PKII 955	700	892	4 x 1/2"	VD115-11	
7	1	PKII 555	2300	1872	4 x 1/2"	VD115-28	
8	1	PKII 455	1500	983	4 x 1/2"	VD115-28	
9	4	PKII 455	1400	917	4 x 1/2"	VD115-11	
10	1	PKII 455	1300	852	4 x 1/2"	VD115-11	
11	16	PKII 455	1200	786	4 x 1/2"	VD115-11	
12	3	PKII 455	800	524	4 x 1/2"	VD115-11	
13	1	PKIII 955	700	1353	4 x 1/2"	VD115-28	
14	7	PKIII 655	1100	1552	4 x 1/2"	VD115-28	
15	3	PKIII 555	1100	1360	4 x 1/2"	VD115-28	
16	1	PKIII 455	2000	1988	4 x 1/2"	VD115-46	
17	1	PKIII 455	1700	1690	4 x 1/2"	VD115-28	
18	1	PKIII 455	1500	1491	4 x 1/2"	VD115-28	
19	4	PKIII 455	1400	1392	4 x 1/2"	VD115-28	
20	25	PKIII 455	1300	1292	4 x 1/2"	VD115-28	
21	11	PKIII 455	1200	1193	4 x 1/2"	VD115-28	
22	4	PKIII 455	1100	1093	4 x 1/2"	VD115-28	
23	8	PKIII 455	800	795	4 x 1/2"	VD115-11	
24	15	PKIII 455	700	696	4 x 1/2"	VD115-11	
25	1	3-30	1200	487	4 x 1/2"	VD115-11	Monteres under loft
26	3	3-32	2700	1460	4 x 1/2"	VD115-28	Monteres under loft
27	2	3-32	2100	1136	4 x 1/2"	VD115-28	Monteres under loft
28	2	3-32	1500	815	4 x 1/2"	VD115-11	Monteres under loft
29	2	3-32	1100	602	4 x 1/2"	VD115-11	Monteres under loft
30	2	3-32	1000	548	4 x 1/2"	VD115-11	Monteres under loft

RADIATORLISTE

Nr.	Stk.	Type Hudevad	Længde mm	Eff. ydelse Δt 30 °C	Anboringer	Radiator ventil	Bemærkninger
31	3	Symphony 600	2000	758	1/2" DC B	VD115-11	Monteres lodret
32	2	Symphony 600	2000	758	1/2" CD A	VD115-11	Monteres lodret
33	3	Symphony 600	1920	728	1/2" DC B	VD115-11	Monteres lodret
34	2	Symphony 600	1920	728	1/2" CD A	VD115-11	Monteres lodret
35	3	Symphony 600	1600	607	1/2" DC B	VD115-11	Monteres lodret
36	2	Symphony 600	1600	607	1/2" CD A	VD115-11	Monteres lodret
37	2	Symphony 500	2080	654	1/2" DC B	VD115-11	Monteres lodret
38	6	Symphony 500	1600	503	1/2" DC B	VD115-11	Monteres lodret
39	6	Symphony 500	1600	503	1/2" CD A	VD115-11	Monteres lodret
40	1	Symphony 500	1520	477	1/2" DC B	VD115-11	Monteres lodret
41	2	Symphony 400	2000	438	1/2" DC B	VD115-11	Monteres lodret

Calt

163

+ 3 nye i baghus-skoven.

166

Århusgade 23-27 / Randersgade 55, 2100 København Ø

Centralvarme
Radiatorliste

TEGNET: MW	MÅL: 1:-	DATO: 30.05.1997	SAG NR.	TEGN NR.
BEREGN.: LD	A	B	C	D
KONTR.: LD	E	F	G	H
			3493A	1.08

VAGN DUER rådgivende ingeniørfirma A/S // LANDSEBAKKEN 10 · 2840 HOLTE · Telefon 42423568